

**N.C. DENR Situation Report 2 p.m. for Sunday, Aug. 28, 2011**

WATER QUALITY      WASTE MANAGEMENT      PARKS AND RECREATION      AQUARIUMS – R, PK, FF  
REGIONAL OFFICES      AIR QUALITY      COASTAL MANAGEMENT      LAND RESOURCES  
MARINE FISHERIES      WATER RESOURCE

**WATER QUALITY**

**Current Issues**

***Coastal Wastewater Treatment Systems***

- Bertie Co. – Aulander – sewer system overflow – lost 5,000 gallons from a manhole.
- Bertie Co. – Windsor – Reporting several sewer system overflows.
- Dare Co. – Manteo – most of the sewer system collection system underwater. The wastewater treatment plant is surrounded by water but still functioning.
- Jones Co. – Maysville – The treatment plant is overwhelmed by floodwaters and the plant is losing solids. System providing only partial treatment.
- Lenoir Co. – Kinston/Neuse Regional treatment plant - overwhelmed by flood waters and the plant is losing solids. System providing only partial treatment.
- Onslow Co. – Onslow Water and Sewer Authority – The town of Holly Ridge wastewater treatment and land application system – heavy flow causing bypass before UltraViolet (UV) sanitizing process at the treatment plant
- Pitt Co. – Bethel – pumps wastewater to Greenville; currently pumps at Bethel unable to keep up with volume of water. Have wastewater contained in a two acre area near the pumps. Are getting additional pumps to help.
- Pitt Co. – Winterville – reported that last night there were four overflowing pump stations.
- Washington Co. – Plymouth – reports several sewer system overflows
- Wayne Co. – Goldsboro – reports several sewer system overflows

***Marinas***

- DWQ working with Environmental Protection Agency and US Coast Guard:
  - USCG Gulf Coast Strike team concentrating on New Bern (Craven Co.) and Oriental (Pamlico Co.)
  - Have received reports that McCotters Marina and Washington Yacht and Country Club, both in Washington, have sustained heavy damage

**Raleigh Regional Office -**

In response to Hurricane Irene, on Sunday morning, Aug. 28, 2011, the DWQ Raleigh Regional Office staff contacted major municipal, minor, industrial wastewater treatment systems and wastewater collection systems for both discharge and non-discharge systems. The below listed account is provided for your consideration:

- Person County \* - See bolded Asterisks below
- Orange County\* - See bolded Asterisks below
- Chatham County\* - See bolded Asterisks below
- Durham County\* -See bolded Asterisks below
- Granville County\* -See bolded Asterisks below
- Lee County\* -See bolded Asterisks below
- Vance County\* -See bolded Asterisks below
- Warren County\* -See bolded Asterisks below
- Wake County \* – No reported wastewater infrastructure failures (Note: one sewer system overflow in Cary reported, but it was not related to storm event.) Note: Zebulon (Little Creek WASTEWATER TREATMENT PLANT - operated by city of Raleigh is still on generator.)

\*Several facilities explained that they experienced periodic power outages and that they switched over to backup generators. NO report of storm event damage to wastewater plant, collection system or storm-related sewer system overflows.

### **Edgecombe County**

- Macclesfield – plant on generator power – no spills or issues.
- Pine Tops – no problems with sewage – plant and stations are on generator power. Major damage to town. More fuel for generators is on the way.
- Tarboro – Tarboro wastewater treatment plant and collection system are doing well - no problems - expect to be on generator power for a couple of days - refueling will be conducted today to all generators. No overflows reported. Plant is handling flow.
- Princeville – One overflow – amount and status will be reported (sewer overflow has stopped). All stations are on generator power and none of the lift-stations are inundated/flooded. More fuel is on the way for the generators.

### **Franklin County:**

- Novozymes – no problems reported.
- Bunn- During event Bunn experienced power outages and used back-up generators. NO treatment unit failure or sewer system overflows occurred. Power is restored.
- Franklin County Water Reclamation – No problems reported
- Louisburg wastewater treatment plant – During storm event they switched over to generators. They currently have power, operating without generators, and have no structural issues or wastewater overflows.

### **Johnston County-**

- Kenly – unable to contact
- Johnston County – unable to contact
- Clayton – unable to contact
- Princeton – was on generator power for a period of time 8/27/11. No problems.
- Benson – no problems – only on generator power for 2 hours 8/27/11
- Smithfield – no problems. Used pump around (bypass) for a period of time 8/27/11.
- Selma – No overflows or problems. All stations have power but 1 – using bypass system (pump around) until power is restored.

### **Northampton County -**

- Seaboard – Wastewater treatment plant has no power. (Non-discharge spray wastewater treatment system )
- Conway - Wastewater treatment plant has no power. (Non-discharge spray wastewater treatment system )
- Woodland - Wastewater treatment plant has no power (Non-discharge spray wastewater treatment system )  
[Sewer System Overflows occurring – No damage to treatment system]
- Rich Square – unable to contact
- Woodland – overflow occurred from Manhole #25 and Lift Station #1 from 11 a.m. 8/27/11 until 6:30 a.m. 8/28/11. May have freeboard issues later but lagoon will not be breached. On generator power.

### **Halifax County**

- Scotland Neck – Bypass at Influent pump station 8/27/11 – has stopped. All stations and wastewater treatment plant are on generator power. Stations that do not have generators are being bypassed to gravity lines (pump arounds).
- Enfield – Generator problems at wastewater treatment plant – only providing 2 phases to influent pump station. Pumps have been shut down and influent is bypassing (overflowing). Electrician is on way to plant. 8 pump stations are on generators and 1 pump station has not been visited. No overflows in the collection system that have been discovered. Town is still in reaction/assessment mode.
- Roanoke Rapids – Plant is at capacity and is on generator power. No issues noted by wastewater treatment plant for the collection system. Still waiting to hear back from collection system ORC.

### Nash County

- Bailey – unable to contact
- Rocky Mount – Fenner Road pump station is overflowing – amount has not been calculated. Manhole at Hill/Cokey Streets has overflowed but has stopped. CDC pump station experienced 4 hour spill 08/27/11. All pump stations but 1 are on generator power. Staff are still evaluating and assessing and SWP will receive an update later today. Wastewater treatment plant (WASTEWATER TREATMENT PLANT) is on generator power but no problems are occurring.
- Nash-Rocky Mount Schools – lost power for a period of time 08/27/11 but no problems are occurring.
- Spring Hope – 2 pump stations overflowed 8/27/11 and approx. 1000 gallons lost at each. Wastewater treatment plant was on generator power but power has been restored to all of the town. No current problems at the WASTEWATER TREATMENT PLANT.
- Nashville – unable to contact

### Wilson County

- Stantonsburg – lost power to WASTEWATER TREATMENT PLANT and main pump station 08/27/11 but it was restored 08/27/11 at 7:51 p.m. Approximately 4,500 gallons spilled at main pump station. No further problems as of 08/28/11. WASTEWATER TREATMENT PLANT is operating normally.
- Wilson – No spills or overflows reported. As of 08/28/11, all pump stations and wastewater treatment plant are on generator power. Wilson Energy is restoring power and they will go off generator power when the main power is stabilized. Contentnea Creek flooded but did not impact wastewater treatment plant; more than 50 MGD of wastewater treated by wastewater treatment plant.
- Elm City – No spills have occurred. Wastewater treatment plant and pump stations have power. Operator will continue to oversee status. Regional Office staff will continue to check with EnviroLink Inc.

Note: Currently, no reported overflows from animal operation lagoons.

All items in bold and underlined are part of next actions plan.

### Next Steps

- In Raleigh Region, all items in bold and underlined are part of next actions plan.
- On the coast, will continue to communicate with permitted facilities and prioritize next actions.

## **WASTE MANAGEMENT**

### **Current Situation**

- In Onslow County, Crowder Gulf Contracting is en route to grind vegetative debris. The temporary disaster debris storage site is still activated from the April tornados. Demolition waste will be direct-hauled to the Onslow County Landfill.
- In Dare County, demolition waste will be hauled directly to the landfill. A temporary disaster debris storage site will be activated on the south end of the Outer Banks. County officials will determine which of the sites they will actually activate. The sites will be managed by Beck Company. Vegetative waste is the primary waste stream that will be handled.
- Hwy. 12 is breached north of Rodanthe. (Mainly wash-over with minor asphalt damage.)
- Franklin County - no temporary disaster debris storage sites needed.
- Halifax County- (Larry Garriss- Solid Waste Director) Many trees down, especially in Roanoke Rapids. Halifax County Landfill temporary disaster debris storage site will be activated as a result.
- Roanoke Rapids reported they had "a mess." The 13<sup>th</sup> Street temporary disaster debris storage site is being activated.
- Johnston County - County Solid Waste Director Rick Proctor reported that there was no need to open any temporary disaster debris sites at this time.
- Chowan County - temporary disaster debris storage site was activated in Edenton at the airport site.

- Bertie County - East Coast Environmental Municipal Solid Waste Landfill activated a temporary disaster debris storage site for vegetative debris.
- Shawn McKee, Solid Waste Section Compliance Officer will be at the EOC today until 6 p.m. **The number for the EOC Solid Waste Desk is (919) 733-3797.**

## **PARKS AND RECREATION**

### **Current Situation**

- Nine of 16 parks in eastern and central N.C. closed in advance of the storm have reopened. Rangers continue to evaluate damage and determine the safety of public areas before they are reopened.
- All affected state parks have done initial damage assessments; no significant damage to facilities or natural resources reported; a number of trees across entrance roads, trails and public areas are being cleared.
- The Central Reservations System for the state parks system is notifying those with reservations about continued closings. Detailed updates are posted on the website, Facebook and Twitter.
- At least five rangers from unaffected parks will soon be deployed to the Dare County/Buxton area for relief efforts.
- Supervisory staff have determined what field staff throughout the state are available for further response.
- Representatives of the ranger operations staff are manning the EOC on a rotating basis and are advising operations supervisors of current conditions.

### **Operational Priorities**

- Field staff will continue making evaluations of damage or potential hazards and will determine what parks may need team assistance for repairs. Damage and labor that may qualify for eventual FEMA reimbursement is being tallied.
- Conference calls are scheduled today and Monday to review reports from parks and to discuss plans for further reopening of parks.

## **AQUARIUMS**

### ***N.C. Aquarium on Roanoke Island***

#### **Current Situation**

No new information since previous situational report.

#### **Current Priorities**

- NCARI staff will continue to feed and care for animals.
- Assess and record damage to aquarium and pier.
- Begin picking up debris from aquarium and pier.
- Awaiting word from Dare County officials to let staff that evacuated back into area so large-scale clean up can begin.

### ***N.C. Aquarium on Pine Knolls Shore***

#### **Current Situation**

- We remain closed to the public
- Have completed damage assessment, significant items include downed trees, damaged asphalt shingles and the loss of sea water intake system
- Remain on generator backup power
- No loss of animal life

#### **Operational Priorities**

- Engage tree service to deal with fallen trees

- Begin repair work to get sea water intake system operational
- Plan replacement of sea water intake pier
- Minor debris cleanup
- Should be able to reopen to the public on Monday

***N.C. Aquarium at Fort Fisher***

**Current Situation**

- All normal business operations have resumed

**REGIONAL OFFICES**

***Washington***

No new information since previous situational report.

***Fayetteville***

No new information since previous situational report.

***Raleigh***

No new information since previous situational report.

***Wilmington***

No new information since previous situational report.

**AIR QUALITY**

**Current Situation**

- Washington regional office now has power, but building has a few small water leaks.
- DAQ staff in WARO weathered the storm OK but some had property damage.

**COASTAL MANAGEMENT**

**Current Situation**

***Elizabeth City District***

- Confirmed inlet cut 4 to 5 miles north of Rodanthe at national park rest stop; near Pea Island National Wildlife Refuge buildings. Approximately 80-100 yards wide. Could be two separate breaches in the same location. Staff coordinating w/ DOT. Understand DOT has a breach repair team assembled.
- Two other NC 12 washouts being reported at Mirlo Beach area (S-curves area) and between Frisco and Hatteras. Staff will coordinate as needed with DOT.
- EC District Manager report: Several areas of flooding. No breach reported at Izzies Inlet, Hatteras Village, but overwash occurred both from the ocean and the sound. In Pasquotank: pier and bulkhead damage, several homes and structures are damaged, trees down in roadways, current (Sun. a.m.) water level is 2-3 ft high. Power is off in many areas.
- House in S. Nags Head where sandbags have not been removed as required are inundated with water, but still standing.

***Washington District***

- No new information since last update.

***Wilmington District***

- Most roads are now open, still have a lot of power outages. Curfews on beaches have been lifted. Damage assessments will begin tomorrow.

### ***Morehead City District***

- MHC District Manager reports that DCM staff in the Down East area of Carteret Co., such as Cedar Island, are reporting massive flooding and damage. Oceana, Sheraton and Bogue Inlet piers have all had their ends knocked off by the storm. Bogue Banks seeing mostly docks and piers damaged, no significant structural damage. DCM staff is in contact with each other.

### ***Coastal Reserves***

- Kitty Hawk office, boat, vehicle fine.
- Can't yet access Currituck Banks site or Buxton due to closed roads.
- Beaufort office sustained some damage and is currently powered by generator, will know later whether the office will be open.
- Wilmington office is powered by generator, no word on whether it will be open tomorrow.
- Evidence of overwash at Masonboro Island, possible impact to turtle nests.

### **Operational Priorities**

- Assist DOT with NC 12 repairs.
- DCM staff will perform further damage assessments on Monday.
- Elizabeth City district manager will decide Monday if satellite DCM office is needed.
- Thorough assessments of reserve sites will begin tomorrow.

## **LAND RESOURCES**

### **Current Situation**

- No problems with dams noted as of 2 p.m. at Emergency Operations Center, Washington, Wilmington and Raleigh Regional Offices.
- Staff at Washington Regional Office reports widespread power outages at home; regional office has power, but some leaky roof damage. No reports of dam problems in Washington Region at time of this sit rep.
- Wilmington Regional Office is standing by for post-event inspections as needed. No reports of dam problems in Wilmington Region as of the time this report.
- Division of Land Resources is currently staffing EOC. Current plan is to staff EOC from 8 a.m.- 8 p.m. and arrange for additional staffing beyond 8 p.m. today on an as-needed basis. Will coordinate with Infrastructure Services functional lead on EOC staffing.

### **Operational Priorities**

- Remain prepared to assign and dispatch inspection teams to problem dam sites, reported or suspected. Assess staff availability for post-event inspections of priority dams in most affected areas.
- Steve McEvoy taking over EOC duty 2 p.m. today.

## **MARINE FISHERIES**

### **Current Situation**

- There still is no electricity in Morehead City and assume none in Elizabeth City and Manteo. We have not heard back from staff checking on the South River facility.
- Marine Patrol communications center is operational on backup generator.
- Preliminary estimates indicate between 600 to 700 tires on the Bogue Banks beaches. Staff is contacting other staff and the prisons for prisoner assistance to see who is available to start tire pickup tomorrow. Staff has also been in contact with town officials on Bogue Banks to let them know we plan to start picking up tomorrow.
- We had one Marine Patrol vehicle suffer flood damage in Pamlico County. All other Marine Patrol equipment is safe.

**Future:**

- We will determine whether DMF offices will open tomorrow or which to keep closed. This will be dependent on whether the offices have electricity and the LAN can be brought back up.
- Also later today we will know if we have enough staff for tire pickup or whether we will need to ask for additional assistance.

**WATER RESOURCES**

**Current Status**

- Regional office staff are in the process of contacting water systems to determine their status.
- Thirty-two systems in Beaufort, Bertie, Brunswick, Carteret, Craven, Lenoir, Martin, New Hanover, Onslow, Pamlico and Pitt counties have issued boil water advisories.
- The attached spreadsheet lists all the systems that have reported their status, except the systems that are operating normally.

## Water System Assessments 8/28/2011

Excluding normal status/no restrictions

County	PWS id	Water System	System Type	Status	Use Restriction	Comments	Population	Admin Contact	Admin Phone	Date Updated	Completed by
BEAUFORT	NC0407597	ASMO WAREHOUSE-SHEPARD MILL R	NON-TRANSIENT NON-COMMUNITY	Unknown	-----	ORC unable to ascertain conditions of water system.	35	WILSON, MIKE		8/28/2011 12:10	Harry Bailey
BEAUFORT	NC0407020	AURORA WATER SYSTEM	COMMUNITY	Operating on backup power	none	No pressure loss. Emergency generators providing power.	571	GROOME, TERRY	252-322-5208	8/28/2011 9:55	Harry Bailey
BEAUFORT	NC0407035	BEAUFORT CO NORTHSIDE REGIONAL	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Likely line break in Ransomville area has drained the Ransomville EST. That section of system has been isolated. Loss of Pressure advisories to be distributed to affected customers. 95% of system is unaffected.	19,441	JETT, CURTIS	252-975-0720	8/28/2011 9:17	Harry Bailey
BEAUFORT	NC0407040	BEAUFORT CO SOUTHSIDE	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Parts of system without pressure have been isolated from rest of system. Two emergency generators are to be delivered from EMS. Loss of Pressure Advisories to be distributed today as well as notification by TV and radio. Still searching for probable line breaks.	9,062	JETT, CURTIS	252-975-0720	8/28/2011 9:10	Harry Bailey
BEAUFORT	NC0407015	BELHAVEN WATER SYSTEM	COMMUNITY	Operating on backup power	none	ORC Brad Lee unable to ascertain conditions at campground.	1,960	GRANT, SONNY	252-943-3055	8/28/2011 9:48	Harry Bailey
BEAUFORT	NC0407501	BILLY K CAMPGROUND	TRANSIENT NON-COMMUNITY	Unknown	-----	ORC Brad Lee unable to ascertain conditions at campground.	180	KINNION, PATRICK		8/28/2011 13:25	Harry Bailey
BEAUFORT	NC0407025	CHOCOWINY WATER SYSTEM	COMMUNITY	Operating on backup power	none	Starting to provide water to the Beaufort County Southside water system.	2,880	HADDOCK, JEFF	252-946-6568	8/28/2011 11:46	Harry Bailey
BEAUFORT	NC0407558	PCS PHOSPHATE-CENTRAL MAINT	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Well may have been flooded. Boil water advisory circulated. System will sample well and distribution system for bacti.	408	SMITH, ROSS	252-322-8283	8/28/2011 11:30	Harry Bailey
BEAUFORT	NC0407545	PCS PHOSPHATE-MILL OFFICE	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory		130	SMITH, ROSS	252-322-8283	8/28/2011 11:00	Harry Bailey
BEAUFORT	NC0407560	PCS PHOSPHATE-PURCH/TECH SERV	NON-TRANSIENT NON-COMMUNITY	Operating on backup power	none		136	SMITH, ROSS	252-322-8283	8/28/2011 11:36	Harry Bailey
BEAUFORT	NC0407559	PCS PHOSPHATE-SPA/FERT	COMMUNITY	Operating on backup power	none		192	SMITH, ROSS	252-322-8283	8/28/2011 11:40	Harry Bailey
BEAUFORT	NC0407525	RIVER FOREST MANOR	TRANSIENT NON-COMMUNITY	Other	none	Interconnected with Town of Belhaven 0407015 due to loss of power and damage to bladder tanks. No loss of pressure.	43	MOORE, REBECCA	252-943-2151	8/28/2011 12:04	Harry Bailey
BEAUFORT	NC0407010	WASHINGTON, CITY OF	COMMUNITY	Operating on backup power	none		11,673	WATERS, STEPHEN ADAM	252-975-9310	8/28/2011 10:58	Harry Bailey
BEAUFORT	NC0407111	WHITLEY'S MHP	COMMUNITY	Unknown	-----	Unable to contact owner/operator.	270	WHITLEY, ROBERT	252-975-6020	8/28/2011 13:14	Harry Bailey
BERTIE	NC0408085	BERTIE COUNTY REGIONAL WATER	COMMUNITY	Operating on backup power	none	System lost primary electrical power, but did not lose pressure - System is operating on backup power Only 1 well lost power, tank was full. No loss of pressure to system and well now back up on emergency power. Collected by J. Roddy	10,742	SPIVEY SR, RICKY K	252-794-4427	8/28/2011 9:18	Michael Douglas
BERTIE	NC0408055	CLEARWATER VALLEY WATER ASSOC	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	System lost primary electrical power and list system pressure - still w/o primary or backup power	66	COBURN, WILLIAM EARL	252-794-2331	8/28/2011 8:57	Michael Douglas
BERTIE	NC0408040	POWELLSVILLE, TOWN OF	COMMUNITY	No Power		System operating by interconnection to another system not on advisory or notice	784	ASBELL, THOMAS	252-332-5933	8/28/2011 9:31	Michael Douglas
BRUNSWICK	NC7010054	CHADWICK MHP	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	reported by Bryan Chadwick. System lost power and pressure during the night but has power and normal pressure now.	90	CHADWICK, KLARA	910-371-3373	8/27/2011 13:13	Diane Williams
BRUNSWICK	NC0410130	THE VILLAGE OF BALD HEAD ISLAN	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	8/27 reported by David Suther. Due to extended power outages overnight and issues with the sewer lift stations and individual home grinder pumps, the system shut down water service early am to reduce the risk of sewer backups into the homes. Both the sewer and water systems are operating normally now. A Boil Water Advisory has been issued by the system.	2,442	BOWLING, KENNITH	910-457-7351	8/27/2011 14:20	Diane Williams
CAMDEN	NC0415015	SOUTH CAMDEN WTR & SWR DISTRICT	COMMUNITY	Operating on backup power		system los primary electrical power, but did not lose system pressure - System operating on backup power	4,793	CREDLÉ, DAVID	252-207-6874	8/28/2011 9:10	Michael Douglas
CARTERET	NC0416035	ATLANTIC BEACH, TOWN OF	COMMUNITY	Operating on backup power	none		6,380	SCHULZE, MARC	252-726-1366	8/28/2011 12:37	
CARTERET	NC0416160	ATLANTIC MHP	COMMUNITY	No Power	Boil Water Advisory		113	WIEDNER, DANNY	252-223-4941	8/28/2011 13:20	
CARTERET	NC0416166	ATLANTIC MHP II	COMMUNITY	No Power	Boil Water Advisory		106	WIEDNER, DANNY	252-223-4941	8/28/2011 13:20	
CARTERET	NC0416192	ATLANTIC VILLAGE MHP	COMMUNITY	No Power	Boil Water Advisory		175	WIEDNER, DANNY	252-223-4941	8/28/2011 13:21	
CARTERET	NC0416101	BALLOU MHP	COMMUNITY	No Power	Boil Water Advisory		95	BALLOU, GEORGE	252-726-2138	8/28/2011 13:20	
CARTERET	NC0416010	BEAUFORT, TOWN OF	COMMUNITY	Operating on backup power	none		4,690	YOUNG, JOHN	252-728-7166	8/28/2011 13:19	
CARTERET	NC0416140	DOC'S MHP NO 2	COMMUNITY	No Power	Boil Water Advisory		56	WEISS, KEN	252-223-4973	8/28/2011 13:15	

CARTERET	NC0416165	EAGLE'S NEST MHP	COMMUNITY	No Power	Boil Water Advisory		60	ROBERSON, GARY	252-223-5820	8/28/2011 13:22	
CARTERET	NC0416025	HARKERS ISLAND SANITARY DIST	COMMUNITY	Operating on backup power	none		2,229	DAVIS, TRAVIS	252-727-2252	8/28/2011 12:49	
CARTERET	NC0416186	HUNTING ESTATES	COMMUNITY	No Power	Boil Water Advisory		80	WIEDNER, DANNY	252-223-4941	8/28/2011 13:21	
CARTERET	NC0416205	LAKE ROAD MHP	COMMUNITY	No Power	Boil Water Advisory		40	ROBERSON, GARY	252-223-5820	8/28/2011 13:28	
CARTERET	NC0416142	LIGHTHOUSE WAY MHP & APTS	COMMUNITY	No Power	Boil Water Advisory		90	ROBERSON, GARY	252-223-5820	8/28/2011 13:28	
CARTERET	NC0416198	MERRIMON WATER SYSTEM	COMMUNITY	Operating on backup power	none		71	CAHOON, TONY	252-728-8955	8/28/2011 13:05	
CARTERET	NC0416015	MOREHEAD CITY, TOWN OF	COMMUNITY	Operating on backup power	none	have enough fuel for one day; unable to contact fuel hauler	9,022	WILLIAMS, DANIEL	252-726-5022	8/28/2011 12:53	
CARTERET	NC0416172	NEWPORT RIDGE MHP	COMMUNITY	No Power	Boil Water Advisory		74	WIEDNER, DANNY	252-223-4941	8/28/2011 13:21	
CARTERET	NC0416020	NEWPORT WATER SYSTEM	COMMUNITY	Operating on backup power	none		3,750	DULANEY, CLAY	252-223-3400	8/28/2011 13:07	
CARTERET	NC0416197	NORTH RIVER/MILL CREEK WATER S	COMMUNITY	Operating on backup power	none		2,374	CAHOON, TONY	252-728-2904	8/28/2011 13:00	
CARTERET	NC0416031	PINE KNOLL SHORES	COMMUNITY	Operating on backup power	none		4,000	RUDDOLPH, ERNIE	252-247-4353	8/28/2011 12:36	
CARTERET	NC0416182	ROBERSON'S MHP	COMMUNITY	No Power	Boil Water Advisory		99	ROBERSON, GARY	252-223-5820	8/28/2011 13:29	
CARTERET	NC0416174	SEAGATE I	COMMUNITY	No Power	Boil Water Advisory	Utility unable to access system until today. System out of water. Generator being installed this morning with system repressurized, flushed, sampled, etc.	335	WILLIAMS, DON	877-987-2782	8/28/2011 9:47	Diane Williams
CARTERET	NC0416187	SEAGATE IV	COMMUNITY	No Power	Boil Water Advisory	Utility unable to access system until today. No water pressure. Generator being installed today with system repressurized, flushed, sampled, etc.	105	WILLIAMS, DON	910-270-1412	8/28/2011 9:55	Diane Williams
CHOWAN	NC0421015	CHOWAN CO WATER SYSTEM	COMMUNITY	Operating on backup power	none	One well operating on backup power, others wells are fine	10,187	BULLS, THOMAS	252-482-7477	8/28/2011 10:42	Michael Douglas
CHOWAN	NC0421010	EDENTON, TOWN OF	COMMUNITY	Operating on backup power	none		5,500	NEWBERN, PARKER	252-482-4111	8/28/2011 10:31	Michael Douglas
COLUMBUS	NC0424050	BOLTON, TOWN OF	COMMUNITY	Operating on backup power	none	Reported by Wilbur Williams to Byron Reeves. System is using generator at well. Pressure has been maintained throughout system. Will be notified when power has been restored.	750	WILLIAMS, WILBUR A	910-454-0512	8/28/2011 13:08	
Craven	NC0425045	COVE CITY, TOWN OF	COMMUNITY	No Power	Boil Water Advisory		433	GASKINS, SONJA	252-633-1595	8/28/2011 10:49	Harry Bailey
Craven	NC0425055	Craven County Water System	COMMUNITY	Operating on backup power	none		31,000	HAYES, RUSTY (ROY)	252-636-6615	8/28/2011 9:25	Harry Bailey
Craven	NC0425025	DOVER, TOWN OF	COMMUNITY	Operating on backup power	none		418	CAULEY, CHARLES W	252-939-3375	8/28/2011 9:46	Harry Bailey
Craven	NC0425132	FAIRFIELD HARBOR	COMMUNITY	Operating on backup power	none		4,597	ROLLINS, MARY	704-319-0519	8/28/2011 9:47	Harry Bailey
Craven	NC0425040	FIRST CRAVEN SANITARY DISTRICT	COMMUNITY	Operating on backup power	none		6,350	RIGGS, EDWARD	252-633-6500	8/28/2011 9:01	Harry Bailey
Craven	NC0425015	HAVELOCK WATER SYSTEM	COMMUNITY	Operating on backup power	none		13,947	FREEMAN, JIM	252-444-6400	8/28/2011 10:04	Harry Bailey
Craven	NC0425035	MARINE CORPS AIR STATION CHERR	COMMUNITY	Operating on backup power	none		18,181	CHADWICK, JOHNNIE	252-466-5334	8/28/2011 9:53	Harry Bailey
Craven	NC0425010	NEW BERN, CITY OF	COMMUNITY	Operating on backup power	none		34,685	HUGHES, JORDAN	252-636-4057	8/28/2011 10:04	Harry Bailey
Craven	NC0425127	SANDERSON'S MHP	COMMUNITY	Operating on backup power	none		80	SANDERSON, DEL	252-636-4057	8/28/2011 9:46	Harry Bailey
Craven	NC0425113	TOWN OF RIVER BEND	COMMUNITY	Operating on backup power	none		3,101	MASSENGILL, CHRISTINA	252-638-3540	8/28/2011 11:54	Harry Bailey
Craven	NC0425020	VANCEBORO WATER SYSTEM	COMMUNITY	Operating on stored Water only	none		1,864	EDWARDS, VERNON	252-244-0919	8/28/2011 8:47	Harry Bailey
CURRITUCK	NC0427123	CURRITUCK CLUB WATER COMPANY	COMMUNITY	Operating on backup power	none		869	CARAWAN, BENJAMIN	252-453-2370	8/28/2011 10:20	Michael Douglas
CURRITUCK	NC0427010	CURRITUCK COUNTY WATER SYSTEM	COMMUNITY	Operating on backup power	none	System lost primary electrica power, but did not lose system pressure - System operating on backup power	12,494	IRWIN, PAT	252-232-6061	8/28/2011 9:22	Michael Douglas
CURRITUCK	NC0427105	OCEAN SANDS DEVELOPMENT	COMMUNITY	Operating on backup power	none		2,423	CARAWAN, BENJAMIN	252-453-2370	8/28/2011 10:08	Michael Douglas
CURRITUCK	NC0427015	PINE ISLAND UTILITIES	COMMUNITY	Operating on backup power	none		744	CARAWAN, BENJAMIN	252-453-2370	8/28/2011 9:51	Michael Douglas
CURRITUCK	NC0427101	SANDY POINT RESORT & CAMPGROUN	COMMUNITY	Operating on backup power	none		559	JONES, YAMA	8/28/2011 9:50	Michael Douglas	
CURRITUCK	NC6027001	SOUTHERN OUTER BANKS WTR SYST	COMMUNITY	Operating on backup power	none		5,433	CARAWAN, BENJAMIN	252-453-2370	8/28/2011 10:41	Michael Douglas
DARE	NC0428126	CAMP HATTERAS	TRANSIENT NON-COMMUNITY	Unknown	Other Provide Explanation	Campground in Rodanthe. Could not contact ORC or owner.	1,064	WELLS, JEFF	252-987-2777	8/28/2011 9:44	Harry Bailey
DARE	NC0428025	DARE CO-CAPE HATTERAS WATER	COMMUNITY	Operating on backup power	none		5,486	FLATT, KEN	252-475-5606	8/28/2011 8:27	Harry Bailey
DARE	NC0428035	DARE CO-RWS WATER SYSTEM	COMMUNITY	Operating on backup power	none		1,808	FLATT, KEN	252-475-5606	8/28/2011 8:26	Harry Bailey
DARE	NC6028002	DARE CO-STUMPY POINT WATER SYS	COMMUNITY	Operating on backup power	none		269	SELBY, PAUL	8/28/2011 9:22	Harry Bailey	
DARE	NC0428030	DARE COUNTY WATER SYSTEM	COMMUNITY	Operating on backup power	none		22,766	FLATT, KEN	252-475-5606	8/28/2011 8:27	Harry Bailey
DARE	NC0428415	FORT RALEIGH-CAPE HATTERAS NS	NON-TRANSIENT NON-COMMUNITY	Unknown	Other Provide Explanation	Park is closed. Unable to contact ORC or park staff at this time.	40	ROLLINSON, SHELLY	252-995-5032	8/28/2011 9:54	Harry Bailey
DARE	NC0428015	KILL DEVIL HILLS, TOWN OF	COMMUNITY	Operating on backup power	none		6,800	TAWES, DAVID	252-480-4088	8/28/2011 8:40	Harry Bailey
DARE	NC0428010	NAGS HEAD, TOWN OF	COMMUNITY	Operating on backup power	none		3,125	CARAWAN, NANCY R	252-449-4210	8/28/2011 8:36	Harry Bailey
DARE	NC6028005	THE REFUGE ON ROANOKE ISLAND	TRANSIENT NON-COMMUNITY	Closed w/ significant damage	Other Provide Explanation	Campground is closed and system will be assessed when conditions allow.	163	FEARING, MALCOLM	252-473-2208	8/28/2011 9:39	Harry Bailey
DARE	NC0428462	WANCHESE SEAFOOD INDUSTRY PARK	NON-TRANSIENT NON-COMMUNITY	Operating on stored Water only	none	Commercial Park is closed and water system is maintaining pressure via elevated storage.	300	TWIDDY, TOMMY	252-480-5514	8/28/2011 9:17	Harry Bailey
DUPLIN	NC0431020	BEULAVILLE, TOWN OF	COMMUNITY	Operating on backup power	none	Reported by Stanley Miller to Byron Reeves. System is without power and is using generators at their wells. Pressure has been maintained throughout. Will be contacted when power is restored.	1,115	SUMMERLIN, SCOTTY	910-298-4647	8/28/2011 10:07	
DUPLIN	NC0431040	FAISON, TOWN OF	COMMUNITY	Operating on backup power	none	Reported by Stanley Miller to Byron Reeves. System is without power and is using generators at their well. Pressure has been maintained throughout. Will be contacted when power is restored.	1,250	FLAKE, ELMER	910-267-2721	8/28/2011 10:06	
DUPLIN	NC0431015	WARSAW, TOWN OF	COMMUNITY	Operating on backup power	none	Reported by Stanley Miller to Byron Reeves. System is without power and is using generators at their wells. Pressure has been maintained throughout.	3,228	STEIGERWALE, JR	910-293-7814	8/28/2011 10:05	

GATES	NC0437020	GATES COUNTY WATER SYSTEM	COMMUNITY	Operating on backup power	none	Will connect to Greene County if level in elevated tank drops.	9,342	HEDGEPEETH, TIMOTHY	252-357-2411	8/28/2011 8:25	Harry Bailey
GREENE	NC0440020	HOOKERTON, TOWN OF	COMMUNITY	Operating on stored Water only	none		716	TAYLOR, BOBBY	252-747-3816	8/28/2011 10:19	Harry Bailey
GREENE	NC0440022	JASON WATER CORPORATION	COMMUNITY	Other	none	Lost line power and opened interconnection with Greene County. Did not lose pressure.	628	SUTTON, JAMES	252-747-3414	8/28/2011 10:43	Harry Bailey
GREENE	NC0440045	LIZZIE WATER CORPORATION	COMMUNITY	Unknown	Other Provide Explanation	Unable to contact system.	64	BEAMAN, HENRY P	252-753-5361	8/28/2011 10:51	Harry Bailey
HALIFAX	NC0442025	ENFIELD WATER SYSTEM	COMMUNITY	Operating on backup power	none		2,250	DAVIS, BOBBY	252-445-3146	8/28/2011 13:22	Allen Hardy
HALIFAX	NC0442010	ROANOKE RAPIDS SANITARY DIST	COMMUNITY	Operating on backup power	none		23,017	BENNETT, JOE B	252-537-3319	8/28/2011 13:26	Michael Douglas
HALIFAX	NC0442020	WELDON WATER SYSTEM	COMMUNITY	No Power	none	No advisory needed - Weldon has an interconnect to RRSC, if needed.	1,375	CROWDER, DONALD	252-536-3478	8/28/2011 13:21	Michael Douglas
HERTFORD	NC0446040	HARRELLSVILLE, TOWN OF	COMMUNITY	Operating on backup power	none		843	MABRY, JERRY	252-356-2566	8/28/2011 13:27	Michael Douglas
HERTFORD	NC0446045	HERTFORD COUNTY RURAL WATER	COMMUNITY	Operating on backup power	none		7,299	NICHOLS, MELVIN R	252-358-7867	8/28/2011 9:37	Michael Douglas
HERTFORD	NC0446025	MILLENNIUM WATER ASSOCIATION	COMMUNITY	Operating on backup power	none		711	JONES, KENNETH O	252-346-0031	8/28/2011 10:00	Michael Douglas
HERTFORD	NC0446429	MT SINAI BAPTIST CHURCH	TRANSIENT NON-COMMUNITY	Unknown	-----		150	GIBBONS, WALTER	252-346-0031	8/28/2011 13:30	Michael Douglas
HERTFORD	NC0446015	MURFREESBORO, TOWN OF	COMMUNITY	Operating on backup power	none		3,645	BYRD, GENE	252-398-4888	8/28/2011 13:27	Michael Douglas
HERTFORD	NC0446106	UNION UTILITIES CORP	COMMUNITY	Other Provide Explanation	-----	System operating by interconnection to another system not on advisory or notice	482	CANNETTE, JAMES	252-358-3041	8/28/2011 10:28	Michael Douglas
HERTFORD	NC0446001	WEST CHOWAN BAPT ASSOCIATION	TRANSIENT NON-COMMUNITY	Unknown	-----		25	POND, JOHN S	252-332-3235	8/28/2011 13:29	Michael Douglas
HERTFORD	NC0446020	WINTON, TOWN OF	COMMUNITY	Operating on backup power	none		938	PIERCE, CARL	252-358-3041	8/28/2011 9:53	Michael Douglas
HYDE	NC0448010	HYDE COUNTY WATER SYSTEM	COMMUNITY	Operating on backup power	none		5,146	THOMAS, ROBERT	252-926-4196	8/28/2011 8:28	Harry Bailey
HYDE	NC0448020	OCRACOKE SANITARY DISTRICT	COMMUNITY	Unknown	Other Provide Explanation	No contact with water system.	800	TOLSON, DAVID	252-928-5791	8/28/2011 12:10	Harry Bailey
JONES	NC0452010	MAYSVILLE, TOWN OF	COMMUNITY	Operating on backup power	none		1,002	GURGANUS-MCCULLOUGH, DALE	910-743-4441	8/28/2011 12:03	Harry Bailey
JONES	NC0452015	POLLOCKSVILLE, TOWN OF	COMMUNITY	Operating on backup power	none		750	CHADWICK, JOHNNIE J	252-224-9831	8/28/2011 11:48	Harry Bailey
LENOIR	NC0454030	DEEP RUN WATER CORPORATION	COMMUNITY	Operating on backup power	none		12,693	GRAY, BILL	252-568-3006	8/28/2011 11:43	Harry Bailey
LENOIR	NC6054002	FOUNTAIN PARK S/D #1	NON-PUBLIC	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Lost primary line power, no backup available, no water pressure.	23	TAYLOR, RANDY	815-509-3785	8/28/2011 11:50	Harry Bailey
LENOIR	NC6054003	FOUNTAIN PARK S/D #2	NON-PUBLIC	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Lost primary line power, no backup available, no water pressure	20	TAYLOR, RANDY	815-509-3785	8/28/2011 11:48	Harry Bailey
LENOIR	NC0454127	JACKSON HEIGHTS MHP	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory		241	ALBRITTON, MELVIN	252-527-8352	8/28/2011 11:44	Harry Bailey
LENOIR	NC0454015	LAGRANGE WATER SYSTEM	COMMUNITY	Operating on backup power	none		3,167	SUTTON, WESLEY	252-566-3295	8/28/2011 11:15	Harry Bailey
MARTIN	NC0459025	HAMILTON, TOWN OF	COMMUNITY	No Power	none	System operating by interconnection to another system not advisory or notice	520	FREEMAN, WILLIAM	252-798-2001	8/28/2011 9:32	Michael Douglas
MARTIN	NC0459030	JAMESVILLE, TOWN OF	COMMUNITY	Operating on backup power	none		470	MARTIN, ERIC	252-792-5006	8/28/2011 9:51	Michael Douglas
NASH	NC0464010	ROCKY MOUNT, CITY OF	COMMUNITY		none	System lost primary electrical power, but did lose system pressure - Primary power has been restored	57,158	VAN HOOSE, JAY	252-972-1336	8/28/2011 13:24	Michael Douglas
NEW HANOVER	NC0465010	CFPUA-WILMINGTON	COMMUNITY	Operating on backup power	none	The System went off the grid onto back up power as a safety precaution prior to the storm. The system will proceed with split loading between the 2500kw and 1250kw generators until Monday morning.	132,936	RICHARDSON, MIKE	910-332-6739	8/27/2011 13:11	forina.brown@ncdenr.gov
NEW HANOVER	NC0465179	NORTHSIDE MHP	COMMUNITY	Unknown		Left message with system owner and operator	180	KUBECK, BRUCE	910-392-5648	8/27/2011 18:20	
NEW HANOVER	NC0465211	OYSTER POINT S/D	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	Reported by Tim Waddell to Heidi Cox. System lost pressure. Will collect samples as soon as lab is open.	99	WADDELL, TIM		8/27/2011 16:21	
NEW HANOVER	NC0465153	TOWN & COUNTRY MHP NO 1	COMMUNITY	No Power	Boil Water Advisory	Reported by Wilbur Williams to Heidi Cox. System currently has no power. Loss of pressure advisory will be issued instructing residents to boil water once water is restored. Per system owner, Currently no residents are at MHP due to power outage. Coliform samples will be collected.	75	ROBBINS, JERRY	910-392-1957	8/28/2011 12:23	
NEW HANOVER	NC0465163	TOWN & COUNTRY MHP NO 2	NON-PUBLIC	No Power	Boil Water Advisory	Reported by Wilbur Williams to Heidi Cox. System has no power. System is currently on a Boil Water Advisory due to a previous problem. Samples will be collected Monday to determine if Advisory can be rescinded.	24	ROBBINS, JERRY	910-392-1957	8/28/2011 12:35	
NORTHAMPTON	NC0466025	CONWAY, TOWN OF	COMMUNITY	Other	none	System lost primary electrical power, but did not lose system pressure - System operating by interconnection to another system not on advisory or notice	711	LONG, JEFF	252-585-0488	8/28/2011 13:17	Allen Hardy
NORTHAMPTON	NC0466010	JACKSON, TOWN OF	COMMUNITY	No Power	none	System operating by interconnection to another system nor on advisory or notice	532	YOUNG, JOHN	252-534-3811	8/28/2011 13:19	Allen Hardy
NORTHAMPTON	NC0466113	NORTHAMPTON-GASTON	COMMUNITY	Operating on backup power	none		1,186	MARTIN, BILLY	252-534-6341	8/28/2011 9:34	Allen Hardy
NORTHAMPTON	NC0466110	NORTHAMPTON-LAKE GASTON	COMMUNITY	Operating on backup power	none		3,640	MARTIN, BILLY	252-534-6341	8/28/2011 9:34	Allen Hardy
NORTHAMPTON	NC0466108	NORTHAMPTON-MILWAUKEE	COMMUNITY	Operating on backup power	none		5,715	MARTIN, BILLY	252-534-6341	8/28/2011 9:45	Allen Hardy
NORTHAMPTON	NC0466001	NORTHAMPTON-N GASTON	COMMUNITY	Operating on backup power	none		198	MARTIN, BILLY	252-534-6341	8/28/2011 9:46	Allen Hardy
NORTHAMPTON	NC0466045	NORTHAMPTON-PROGRESSIVE	COMMUNITY	Operating on backup power	none		1,958	MARTIN, BILLY	252-534-6341	8/28/2011 9:43	Allen Hardy
NORTHAMPTON	NC0466002	NORTHAMPTON-W JACKSON	COMMUNITY	Operating on backup power	none		40	MARTIN, BILLY	252-534-6341	8/28/2011 9:42	Allen Hardy
NORTHAMPTON	NC0466015	SEVERN, TOWN OF	COMMUNITY	Operating on backup power	none		350	LASSITER, M E	252-585-0411	8/28/2011 13:20	Allen Hardy

ONSLow	NC0467164	SHERWOOD MHP	COMMUNITY	Other	Boil Water Advisory	System loss pressure and now has power, however, it also had several water line breaks that are being repaired today. Customers have been out of water since yesterday. BWA issued by system.	353	HARTSOE, JOEL	910-451-7190	8/28/2011 9:25	Diane Williams
ONSLow	NC0467048	USMC LEJEUNE-ONSLow BEACH	TRANSIENT NON-COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory	System was shut down during storm. Is being repressurized, flushed and sampled.	320	HARTSOE, JOEL	910-451-7190	8/28/2011 9:33	Diane Williams
PAMLICO	NC0469438	CAMP DON-LEE	TRANSIENT NON-COMMUNITY	Operating on backup power	none		200	BLISS, JOSEPH SAMUEL	252-249-1106	8/28/2011 13:19	Harry Bailey
PAMLICO	NC0469020	ORIENTAL WATER SYSTEM	COMMUNITY	Need Bacti and Cl results to clear advisory	Boil Water Advisory		1,048	MAXBAUER, BOB	252-249-0555	8/28/2011 10:05	Harry Bailey
PAMLICO	NC0469025	PAMLICO COUNTY WATER	COMMUNITY	Unknown	Other Provide Explanation	unable to contact system	16,883	GERARD, AL	252-745-5453	8/28/2011 12:19	Harry Bailey
PENDER	NC0471321	HOLLAND'S GROCERY & CAMPGROUND	TRANSIENT NON-COMMUNITY	Unknown		8/28 left voice messages at contact #s 8/28 No answer at any of contacts' #s; left voice messages to return call.	65	HOLLAND, STEPHEN C	910-259-5743	8/28/2011 12:18	Diane Williams
PENDER	NC7071036	J&S CAMPGROUND NO 1	NON-PUBLIC	Unknown		8/28 left voice messages at contact #s to return PWSS call.	20	MOCK, SANDEE	910-358-5275	8/28/2011 11:49	Diane Williams
PENDER	NC7071037	J&S CAMPGROUND NO 2	NON-PUBLIC	Unknown		8/28 left voice messages w/ contact #s to return call	8	MOCK, SANDEE	910-358-5275	8/28/2011 11:52	Diane Williams
PENDER	NC7071038	J&S CAMPGROUND NO 3	NON-PUBLIC	Unknown		8/27 unable to reach any contacts 8/28 unable to reach any contacts; left voice messages to return calls	16	MOCK, SANDEE	910-358-5275	8/28/2011 11:54	Diane Williams
PENDER	NC0471113	LEA ACRES WATER CO INC	COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back	120	HARVELL, GERALDINE	910-285-7255	8/28/2011 9:44	Diane Williams
PENDER	NC0471439	LONG CREEK GRADY ELEM SCHOOL	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back	68	OGDEN, TODD	910-259-2187	8/28/2011 11:14	Diane Williams
PENDER	NC0471448	MALPASS CORNER ELEM SCHOOL	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back	615	OGDEN, TODD	910-259-2187	8/28/2011 11:16	Diane Williams
PENDER	NC0471442	PENDER HIGH SCHOOL	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back	774	OGDEN, TODD	910-259-2187	8/28/2011 11:23	Diane Williams
PENDER	NC7071010	SCOTTS HILL RETAIL CENTER	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Mr. Lloyd is checking system later today and will call PWSS back if NOT ok as others have reported to him.	70	LLOYD, KENNETH	910-686-1885	8/28/2011 12:14	Diane Williams
PENDER	NC0471462	SOUTH TOPSAIL ELEM SCHOOL	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back	664	OGDEN, TODD	910-259-2187	8/28/2011 11:25	Diane Williams
PENDER	NC7071028	VIRGINIA CREEK CAMPGROUND NO 4	NON-PUBLIC		none		24	KING, ROBERT	910-329-4648	8/28/2011 11:29	Diane Williams
PENDER	NC0471444	WEST PENDER MIDDLE SCHOOL	NON-TRANSIENT NON-COMMUNITY	Unknown		8/28 Operator is checking schools and wells today and will call PWSS back with status	242	OGDEN, TODD	910-259-2187	8/28/2011 11:41	Diane Williams
PITT	NC0474025	AYDEN TOWN OF	COMMUNITY	Unknown	Other Provide Explanation	Unable to contact system.	5,629	SUTTON, ROBERT	252-746-7081	8/28/2011 11:20	Harry Bailey
PITT	NC0474030	BETHEL, TOWN OF	COMMUNITY	Operating on stored Water only	none		1,951	BULLOCK, TODD	252-825-6191	8/28/2011 12:26	Harry Bailey
PITT	NC0474015	EASTERN PINES WATER CORP	COMMUNITY	Operating on backup power	none	currently NRWASA supplied	19,441	SUTTON, BARRY	252-752-7420	8/28/2011 10:06	Harry Bailey
PITT	NC0474050	FOUNTAIN, TOWN OF	COMMUNITY	Operating on stored Water only	none		757	HINES, LETHA	252-749-2881	8/28/2011 8:48	Harry Bailey
PITT	NC0474010	GREENVILLE UTILITIES COMM	COMMUNITY	Operating on backup power	none		95,500	LANGLEY, RICK	252-551-1561	8/28/2011 10:15	Harry Bailey
PITT	NC0474035	GRIFTON, TOWN OF	COMMUNITY	Operating on backup power	none	Currently utilizing water from the Neuse Regional Water & Sewer Authority. Generator at wells sites if needed.	2,854	WILLIAMS, ROBERT	252-524-4081	8/28/2011 10:07	Harry Bailey
PITT	NC0474055	GRIMESLAND, TOWN OF	COMMUNITY	Unknown	Other Provide Explanation	unable to contact system	610	LATHAM, LEE	252-752-6337	8/28/2011 12:24	Harry Bailey
PITT	NC0474060	STOKES REGIONAL WATER CORP	COMMUNITY	Operating on backup power	none		3,150	BLAND, BRUCE	252-757-7751	8/28/2011 10:20	Harry Bailey
PITT	NC0474142	THOMAS MOBILE PARK NO 3	COMMUNITY	No Power	Boil Water Advisory		200	THOMAS, CAROLYN		8/28/2011 10:49	Harry Bailey
TYRRELL	NC0489010	COLUMBIA WATER SYSTEM	COMMUNITY	Operating on backup power	none	System lost primary electrical power, but did not lose system pressure - System operating on backup power	1,089	OLIVER, TIM	252-796-2781	8/28/2011 9:09	Michael Douglas
TYRRELL	NC0489015	TYRRELL COUNTY WATER	COMMUNITY	Operating on backup power	none		3,177	SPENCER, JOHNNY	252-796-0471	8/28/2011 9:26	Michael Douglas
WASHINGTON	NC0494020	CRESWELL TOWN OF	COMMUNITY	Operating on stored Water only	none		480	PLACE, NEAL	252-797-4852	8/28/2011 10:41	Michael Douglas
WASHINGTON	NC0494010	PLYMOUTH WATER SYSTEM	COMMUNITY	Operating on backup power	none		3,960	RASNICK, COBERN	252-793-9466	8/28/2011 10:27	Michael Douglas
WASHINGTON	NC0494015	ROPER WATER SYSTEM	COMMUNITY	Operating on backup power	none		620	FREED, BILL	252-491-5277	8/28/2011 10:39	Michael Douglas
WASHINGTON	NC0494025	WASHINGTON COUNTY WATER SYSTEM	COMMUNITY	Operating on backup power	none		6,583	MCCRAY, CARL	252-793-7545	8/28/2011 10:40	Michael Douglas
WAYNE	NC0496015	MOUNT OLIVE, TOWN OF	COMMUNITY	Operating on backup power	none		5,700	BLANTON, DEEMS	919-658-6213	8/28/2011 10:13	Harry Bailey
WAYNE	NC0496155	WALNUT CREEK VILLAGE	COMMUNITY	Operating on stored Water only	none	Backup generator power and interconnection with Wayne Water Districts on standby if needed.	950	COOK, LOUIS S	919-778-9687	8/28/2011 12:37	Harry Bailey
WILSON	NC0498010	WILSON, CITY OF	COMMUNITY	Operating on backup power	none		48,400	PARKS, BARRY	252-399-2374	8/28/2011 13:26	Michael Douglas